

WORKER SAFETY-6 The project owner shall:

- a. Identify and provide a second access gate for emergency personnel to enter the site. This secondary access gate shall be at least one-quarter mile from the main gate and shall be accessed via a gravel road off the main road near the facility fence line. The location shall be submitted to the Riverside County Fire Department (RCFD) for review and comment and to the CPM for review and approval.
- b. Provide two all-terrain fire engines, as identified and chosen by the RCFD, for emergency personnel to enter the site in the event the access to the plant is unavailable. The applicant will be required to provide funding for replacement of similar equipment based on the 20 year depreciation methodology used by the Riverside County Fire Department throughout the life of the project.
- c. If at some point in the future a second road that can serve as an alternate access road to the project site is built, reviewed by the RCFD and approved by the CPM, the need to provide the all-terrain fire engines or funding for equipment maintenance or replacement would no longer be required.

Verification: At least 180 days prior to the initial receipt of heat transfer fluid on-site, the project owner shall either:

- a. submit proof to the CPM in the form of a signed statement from the Chief of the RCFD that the all-terrain fire engines have been delivered to the RCFD and are acceptable to the RCFD; or
- b. if a second access road is built prior to the purchase of the all-terrain fire engines, the project owner shall submit to the RCFD for review and comment and to the CPM for review and approval plans describing the location and specification for the second road. The project owner shall also provide to the CPM documentation demonstrating that the RCFD approves the alternate road.

At least 60 days prior to the start of site mobilization, the project owner shall submit to the Riverside County Fire Department and the CPM preliminary plans showing the location of a second access gate to the site, a description of how the gate will be opened by the fire department, and a description and map showing the location and composition of the gravel road that will provide access from the main access road to the second access gate. At least thirty (30) days prior to the start of site mobilization, the project owner shall submit final plans to the CPM for review and approval. The final plan submittal shall also include a letter containing comments from the Riverside County Fire Department or a statement that no comments were received.